

**OFFICE: Sub-Divisional Engineer, Water Supply And
Sanitation, Kapurthala, Punjab**

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE**


No. 934

Date: 12/09/2024

It is certified that an inspection team headed by Junior Engineer from Office of The Sub- Divisional Engineer, Water Supply and Sanitation, Kapurthala, Punjab inspected the Akal Academy Dhaliwal Bet, P.O: Dhaliwal Bet, District: Kapurthala, Punjab on 12.09.2024 and found that the Akal Academy Dhaliwal Bet has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & campus as per the norms prescribed by the Central/State/U.T Government.

The above is valid for a period of Twelve months.




Sub-Divisional Engineer
Water Supply and Sanitation
Kapurthala, Punjab

To

Akal Academy Dhaliwal Bet,
Village: Dhaliwal Bet, P.O: Dhaliwal Bet,
District: Kapurthala, Punjab - (144804)


Headmistress
Akal Academy
Dhaliwal Bet (Kapurthala)


Manager/ Authorised Signatory

DISTRICT WATER TESTING LABORATORY, KAPURTHALA

Near Dhaliwal dona, water works, Kapurthala
dwtlkpt@gmail.com

TEST REPORT						
Name & Address of Customer : AKAL ACADEMY (DHALIWAL BET) KAPURTHALA			Customer Reference No.		No : AADB/2023-24/S20 Dated : 11/09/2024	
			Sample Submitted by		MR. GURJINDER SINGH	
			Date of Sample Receipt		11/09/2024	
			Analysis Starting Date		11/09/2024	
			Analysis completion Date		12/09/2024	
Discipline : Chemical Testing, Bacteriological Testing			Group: Water			
ULR No.:				Sample Type :		Water
Test Report No.:		DWTLKPT/2425/00125		Date of Issue :		12/09/2024
Registration no.:		DWTLKPT/REG2425/00435		Condition of Sample :		Unsealed
Collection Point:		Private Submersible		Quantity/Type of Bottle:		1000 ml / Transparent Glass Bottle
Scheme/Source:		Not Mentioned(Not Mentioned)		Location/Depth :		AKAL ACADEMY DHALIWAL BET / NA
Village :		Not Mentioned		Habitation :		Not Mentioned
Block:		Dhlwan		District :		Kapurthala
Latitude :		Not Mentioned		Longitude:		Not Mentioned
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.54	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025 (Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 - 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 - 2023)
5	TDS	349	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO3)	233.64	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO3)	232	200	600	mg/l	IS 3025 (Part 21-2009)(RA 2019) EDTA Method
9	Calcium(Ca)	49.69	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
10	Magnesium(Mg)	26.24	30	100	mg/l	APHA (24th Ed. 2023) Method. 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	30.55	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method
12	Bacteriological Contamination(B)	ABSENT			--	H2S Vial

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduced wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND = Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit 50 ±20%


Headmistress
Akal Academy
Dhaliwal Bet / Kapurthala

Reviewed and Approved By


Mr. Jivesh Kumar
Quality Manager
Authorized Signatory
For, District water Testing Laboratory
Kapurthala

End of the Test Report


Manager/ Authorized Signatory

Page No : 1/1

Scanned with OKEN Scanner

DISTRICT WATER TESTING LABORATORY, KAPURTHALA

Near Dhaliwal dona, water works, Kapurthala
dwtlkpt@gmail.com

To,

AKAL ACADEMY (DHALIWAL BET)
KAPURTHALA

No.: DWTLKPT/2425/00125 Dated : 12/09/2024

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. AADB/2023-24/520 Dated: 11/09/2024

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 11/09/2024. It is request to fill the attached feedback form and send it back to District water Testing Laboratory, Kapurthala

D/A : Test Report



Headmistress
Akai Academy
Dhaliwal Bet (Kapurthala)



Authorized Signatory
For, District water Testing Laboratory
Kapurthala



Manager/ Authorised Signatory